

WATER PUMPS, DRINKING WATER SUPPLY- AUXILIARY PUMP

DESCRIPTION			
RESOURCE CATEGORY	Public Works	RESOURCE KIND	Equipment
OVERALL FUNCTION		COMPOSITION AND ORDERING SPECIFICATIONS	

RESOURCE TYPES			TYPE 1	TYPE 2	TYPE 3	TYPE 4
COMPONENT	METRIC/ MEASURE	CAPABILITY				
Equipment	Description		Self-priming Solids handling to 3" Self contained diesel power supply Automatic start/stop Portable skid/trailer mounted: (6500 lbs)	Self-priming Solids handling to 3" Self contained diesel power supply Automatic start/stop Portable skid/trailer mounted: (4959 lbs)	Self-priming Solids handling to 3" Self contained diesel power supply Automatic start/stop Portable skid/trailer mounted: (3200 lbs)	Self-priming Solids handling to 3" Self contained diesel power supply Automatic start/stop Portable skid/trailer mounted: (1734 lbs)
			NOTES: Not Specified			
Personnel	Trained Operator		1	1	1	1
			NOTES: Not Specified			
Equipment	Example		Godwin CD250M	Godwin CD200M	Godwin CD150M	Godwin CD100M
			NOTES: Not Specified			
Equipment	Pump Capacity (GPM)		3500	2000	2000	700
			NOTES: Not Specified			
Equipment	Suction Side (inches)		10"	8"	6"	4"
			NOTES: Not Specified			
Equipment	Head (ft)		50	35	35	20
			NOTES: Not Specified			
Personnel	Onsite Setup Team		1-2	1-2	1-2	1
			NOTES: Not Specified			

INTERIM GUIDANCE



RESOURCE TYPES			TYPE 5	NO TYPE 6	NO TYPE 7	NO TYPE 8
COMPONENT	METRIC/ MEASURE	CAPABILITY				
Equipment	Description		Self-priming Solids handling to 2" Self contained diesel power supply Automatic start/stop Portable skid/trailer mounted: (1586 lbs)	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			
Personnel	Trained Operator		1	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			
Equipment	Example		Godwin CD80D	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			
Equipment	Pump Capacity (GPM)		300	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			
Equipment	Suction Side (inches)		3"	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			
Equipment	Head (ft)		40	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			
Personnel	Onsite Setup Team		1	Not Applicable	Not Applicable	Not Applicable
			NOTES: Not Specified			

INTERIM GUIDANCE

Superseded



COMMENTS

1. Drinking water supply applications include: Treatment plant, pump stations, inter-tie with other public drinking water supplies, or other sources of supply.
2. Purpose: This pump equipment is intended for incident response and recovery, to protect and preserve human life, health and safety, and to restore post-disaster lifelines.
3. Applications: Temporary emergency mobile pump station needed to return safe drinking water to utility reservoirs and mains.

NOTES

Nationally typed resources represent the minimum criteria for the associated component and capability.

INTERIM GUIDANCE

Superseded